

IPWG: Non-Emergency Disconnection, v3

Industry has requested advanced notice to generator-operators in the event the utility requires disconnection for non-emergency purposes.

The Joint Utilities propose language be added to the SIR, noted below in *green*. Current language is in *blue*.

Section II. Interconnection Requirements

B. Operating Requirements

The generator-owner shall provide a 24-hour telephone *and email/electronic* contact. This contact will be used by the utility to arrange access for repairs, inspection, or emergencies. The utility will make such arrangements (except for emergencies) during normal business hours. *For all required disconnections of the generator-owner's system to facilitate non-emergency utility work on the electric power system, the utility will provide two (2) Business Days advance notice to the generator-owner with an indication of anticipated duration.*